

AMERICAN SOCIETY OF GAS ENGINEERS

**NATIONAL TECHNICAL CONFERENCE
JUNE 5TH, 2012**


**BOILER NO_x EMISSIONS
POLITICS & TECHNOLOGIES**

**GREG DANENHAUER
VICE PRESIDENT ENGINEERING
PARKER BOILER CO.**

PRESENTATION ON BOILER NO_x EMISSION POLITICS & TECHNOLOGIES

- I. THE POLITICS OF NO_x EMISSIONS**
- II. COMBUSTION PROCESS**
- III. NO_x CONTROL TECHNIQUES**
- IV. ENERGY EFFICIENCY**
- V. WHAT'S NEXT**

BOILER DEVELOPMENT



- **IN 1988, SCAQMD RULE 219 CHANGED PERMIT REQUIREMENTS FOR BOILERS**
- **PERMIT THRESHOLD WENT FROM 20MM BTUH TO 2MM BTUH**

THE KEY WORDS & RULES GOVERNING BOILER DECISIONS ARE:

1. BACT (Best Available Control Technology). For AQMD
2. LAER (Lowest Achievable Emission Rate).
3. 219 (Permitting Rule, New & Existing Boilers).
4. Rule 1146 (Retrofit Rule) Boiler \leq 5 Million BTUH.
5. 1146.1 (Retrofit Rules) Boilers $2 \leq$ 5 Million BTUH.
6. 1146.2 (New & Retrofit) Boilers 75,000 - 2.0 Million BTUH.
7. Rule 1121 Water Heaters 0 - 75,000 BTUH.
8. Tune-Up
9. Source Test
10. Boiler Monitoring
11. Fees
12. Clean Fuels

California Air Districts





County	District /Area	Rule #	Date	New Boiler/ Retrofit Rule	Gas Permit Threshold	Oil Permit Threshold	NOx & CO - Gas @ 3% O ₂	NOx & CO - Oil @ 3% O ₂	Exemptions & Notes
Placer County	Placer APCD	231.5	1994	New & Retrofit	5,000,000	5,000,000	30/400	40/400	BACT required if > 10 lbs/day of NOx
Sacramento Metro	SMAQMD			New Boiler	1- 5,000,000	1,000,000	70/400	70/400	BACT required if > 10 lbs/day of NOX NOTE: Boilers 1-5,000,000 require evaluation
				New Boiler	5,000,000+	5,000,000	30/400	40/400	
			8/96	Retrofit	5,000,000	5,000,000	30/?	40/400	
San Diego	SDAPCD	11		New Boiler	5,000,000	1,000,000	30/400	?	
		69.2		Retrofit	5,000,000	1,000,000	30/400	30/400	Exemption - Less than 220,000 Therms use with fuel use data and tune ups.
San Joaquin, Stanislaus, Merced, Madera, Fresno, Kings, Tulare and Kern	San Joaquin APCD	4351		Retrofit	5,000,000	5,000,000	30/400	40/400	Exemption - Less than 90,000 Therms use with fuel use data and tune ups.
				New boiler	5,000,000	?	30/400	?	Exemption - Check with District
San Luis Obispo County	San Luis Obispo APCD	201	1991		2,000,000		30/400		Some Agricultural exemptions apply.
Santa Barbara	Santa Barbara APCD			New Boiler	5,000,000	All Units	30/400	30/400	
			1/21/92	Retrofit	5,000,000	5,000,000	30/400	30/400	Exemption - Less than 90,000 Therms use with fuel use data and tune ups.
Shasta County	Shasta APCD	2.1	1992	New Boiler	1,000,000	1,000,000	70/400	70/400	BACT required if > 25 lbs/day of NOx
		301	1992	Retrofit	5,000,000	5,000,000	70/400	115/400	
Siskiyou County	Siskiyou APCD								
LA, Orange, Riverside and portions of San Bernandino	SCAQMD	219	1988	New Boiler	2,000,000	All Units	(7/9) (50/100)	?	*(CO)50 PPM fire tube 100 PPM water tube
		1146	1989	Retrofit	5,000,000	5,000,000	40/400	40/400	Exemption - Less than 90,000 Therms use with fuel use data and tune ups.
		1146.1	1994	Retrofit	2- 4,999,000	2- 4,999,000	30/400	30/400	Exemption - Less than 18,000 Therms use with fuel use data and tune ups.
		1146.2	Jan. 1, 2000	New	>.4-2.0 MM/ Type 2 Unit		30/400		Manufacturers Certification required.
		1146.2	Jan. 1, 2001	New	>.075-.4 MM/ Type 1 Unit		***55/400		Manufacturers Certification Required ***55 PPM or 40 nanograms per joule NOx generation, test per Rule Test Protocol.
		1146.2	July 1, 2002	Retrofit****	>1-2.0 MM/ Type 2 Unit		30/400		Units manufactured prior to 1992. Exemption: Fuel use < 9000 Therms / year.
		1146.2	Jan. 1, 2005	Retrofit****	>1-2.0 MM/ Type 2 Unit		30/400		Units manufactured 1992 to 1999. Exemption: Fuel use < 9000 Therms / year.
		1146.2	Jan. 1, 2006	Retrofit****	>.4-1.0 MM/ Type 2 Unit		30/400		Exemption: Fuel use < 9000 Therms / year.
Tehama County	Tehama APCD								
Tuolumne County	Tuolumne APCD								

EPA (Clean Air Act)


CARB
(State Standards)



SCAQMD



WHY NO_x

- 1) NO_x (NO & NO₂) is a precursor to Ozone (O₃)
- 2) NO_x is a precursor to Nitrate Aerosol which is 40% of the mass of PM 2.5





SCAQMD NO_x EMISSION SUMMARY

AQMP

NO_x

Total NO_x emitted per day = 1,194 tons


Total from Mobile Sources = 1,040 tons

Total from Stationary Sources = 154 tons

Estimated Emissions from Boiler
less than 2,000,000 BTU = 14.9 tons (1.2%)

Estimated Emissions from Boilers
greater than 2,000,000 BTU = 50-75 tons (6.2%)

ALLOWABLE NO_x LEVEL IN BOILERS
PER SCAQMD 1999 (BACT)
For Boilers over 2,000,000 BTU





South Coast Air Quality Management District

Rule 1110.2 Portable Analyzer Operator Training



1146 Unit Monitoring New Requirement

- As of July 1, 2009
- Monitor at least monthly or 750 hours whichever occurs later
- If passes 3 times then quarterly or 2,000 hours whichever occurs later
- 3 years source test
- No tuning prior to test or during
- Monitor must be certified

Requirements Both Rules

- Monitor must be certified by AQMD on Rule and Procedures
- Monitor test is 15 minutes run time plus response time
- Data log at 15 seconds intervals
- Certified Analyzer
- Pre-Calibration (within 10 days)
- Post-Calibration (must be within spec)
- Record a failed test
- Cannot derate below 2.0MM BTU

California Air Districts




The Case of Shasta County


II. THE COMBUSTION PROCESS

- A.** Combustion
- B.** Factors & Key Words
- C.** Formation of NO_x
- D.** Atmospheric combustion
- E.** Power Burners
- F.** NO_x corrected to 3% O₂
- G.** Typical report (Flue Gas Analysis)

COMBUSTION



AIR = 20.9% OXYGEN + 79.1% NITROGEN



PERFECT COMBUSTION= 10 CU. FT. AIR/ 1 CU. FT. GAS

FLUE GAS

DRAFT

COMBUSTION

CARBON DIOXIDE

EFFECTS OF EXCESS AIR

CARBON MONOXIDE (CO)
(LESS THAN 400 PPM @ 3% O₂)

EFFECTS OF CO

CAUSES OF CO

NO_x EMISSIONS

1. NO_x is formed in all combustion processes known as “Thermal NO_x” and/or “Fuel NO_x”.
2. Fuel NO_x is associated with fuels containing bound Nitrogen (Fuel, Oils, Coal).
3. NO_x consists of 80 to 95% NO the remainder in NO₂.
4. Formed more with increased exposure at high temperatures.

SMOG

1. NO_x reacts with sunlight to produce Ozone & Photochemical smog.

ATMOSPHERIC BOILER DRAFT HOOD





DIAGRAM 1



POWER BURNER

NO_x CORRECTED TO 3%

O₂ = Oxygen Value in Stack

$$\frac{(20.9)-3}{20.9 - O_2} = \text{CF (Correction Factor)}$$

at 7% O₂

$$\frac{20.9-3}{20.9-7} = \frac{17.9}{13.9} = 1.28 = \text{CF}$$

so if NO_x reading is 80 ppm

80 ppm @ 7% O₂ is

$$80 \times 1.28 = 102 \text{ ppm NO}_x \text{ @ 3\% O}_2$$


III. NO_x CONTROL TECHNIQUES
BOILER & BURNER NO_x CONTROL STRATEGIES
FROM LARGE EQUIPMENT

COMBUSTION MODIFICATIONS

- A.** Flue gas re-circulation.
- B.** Staged combustion.
- C.** Low NO_x Burners
- D.** Reduced Air Preheat
- E.** Low excess air
- F.** O₂ Trim

FLUE GAS TREATMENT

- G.** Ammonia or Urea injection
- H.** Selective Catalytic Reduction
- I.** Non-selective Catalytic Reduction
- J.** Electron Beam Radiation
- K.** Chemical Scrubbing










FIGURE 1. Typical flue gas recirculation system









Coen Type DAF Operation of Multi-Staged Low NO_x Burner






FIGURE 3. Selective catalytic reduction





LTO INDUSTRIAL BOILER APPLICATIONS




Figure 1: LTO System Process Diagram


III & IV. NO_x CONTROL TECHNOLOGIES

NO_x CONTROL TECHNIQUES FROM SMALL EQUIPMENT & EFFICIENCY


- A. Premix technology
- B. Radiant & Connective Premix Burners
- C. Atmospheric Low NO_x Burners
- D. High Efficiency Boilers




Pre-mix Radiant and Blue Flame Burners




BLUE FLAME MODE




RADIANT MODE






VARIABLE SPEED APPLICATION
POST MIXING "LVFD" SYSTEM

Atmospheric vs. Low NO_x Boiler









Metal Fiber Burners






POWER-FIN® FEATURES



Applications


- INCLINED WATERTUBE BOILERS AND WATER HEATERS.
- BENT WATERTUBE BOILERS AND WATER HEATERS.
- COPPER FINNED-TUBE WATER HEATERS.
- NEW OR RETROFIT APPLICATIONS.



FUEL/AIR DELIVERY MODULE

Pyromat SB™ installed in typical Atmospheric Boiler.


Immersion Tube Burner







MatriX-Strahlungsbrenner/
MatriX-Katbrenner















HEATER
NO. 2







Benchmark 3.0 Low NOx

BTU Input	3,000,000 BTU/hr.
BTU Output	2,610,000–2,883,000 BTU/hr.
Efficiency	99.4% at low fire with 60°F inlet water
Turn-down Ratio	15:1
Dimensions	79"H x 28"W x 64"D
Gas Requirements	4" W.C. minimum at full load
Weight, Wet	2,580 lbs.

V. WHAT'S NEXT


Burning Questions:

*How to Achieve
Environmental Détente,
Energy Security & Clean Air
in a Combustion Constrained World?*



Baseline NOx Emissions and Federal 1997 Ozone Standard Carrying Capacity

*Data from 2007 AQMP
Including benefits of rules adopted to 2007*



Needed *Additional* NOx Reductions*

by 2023: **75%**

Is such a path
possible in the *real world*

?